



4th Floor, Block No. 11-12, Udyog Bhawan, Gandhinagar, GJ, INDIA
Ph: 079-23257251-54, GST. No. 24AAATG1858Q1ZA

Date: 31-Aug-2024

Digitally signed by Ragin Ravindra Shah
DN: c=IN, o=Personal, title=4505,
pseudonym=a925fb8b114542e5bb4a
d35ee0df1fccc,
2.5.4.20=f2d4874d45a02b76d89e3be
a63b5e95408942de4f9537d48
d7951483, postalCode=380015,
st=Gujarat,
serialNumber=0260a25f77309ae82d
5aebe10f5d7163c81741552ca365cb
407666b464d6, cn=Ragin Ravindra
Shah



4. You shall ensure that the location proposed for installation of the system is shadow free during the entire day and also keep the system clean and dust free for optimum output.
5. You shall sign the connectivity agreement with the DISCOM upon its ascertaining the technical feasibility of the system installation.
6. You shall allow access to your premises by representatives of GEDA/ DISCOM/ CEI for installation of respective meter as per provision of Gujarat Renewable Energy Policy – 2023 and its amendments thereof, if any / inspection/ verification of the system.
7. The respective meter shall be installed in accordance to the technical specifications defined by the DISCOM.
8. The technical specifications of the Solar PV system and all its allied components, shall be mutually agreed between YOU and the INSTALLER selected by you.
9. It is YOUR sole responsibility to ensure and check all the components properly with the selected INSTALLER. In no case, GEDA shall responsible for the delay in installation, sub-standard material, low generation or any issue related to performance and quality. However, it is advisable to always install solar PV system in the shadow free area and with proper sizing and structures for maximum generation. Further, the Applicant shall check the requisite documents and reports from the suitable simulation tools on its own or through the Installer to ascertain the above mentioned points.
10. This Application has been submitted under **Industrial/commercial** Category.
11. The Provision of "Approved List of Models and Manufacturers" (ALMM) & its amendment issued by MNRE from time to time shall be applicable.
12. The Provision & amendment issued by GERC/ EPD from time to time shall be applicable.
13. This project shall be governed by the Gujarat Renewable Energy Policy-2023 and the GERC regulations issued from time to time. The Renewable Energy Generator shall be bound by all the provisions as decided by the GERC.
14. The Applicant, SHREE GYAPRASAD JAIN CHERITABLE TRUST, has given following signed undertaking in the application form for installation of the solar roof top system under this registration.

Ragin
Ravindraba
hai Shah

Digitally signed by Ragin Ravindraba
Shah
DN: c=IN, ou=Personal, o=+905,
pseudoym=2ae9ba114542e5b44
d53eaddfcca
2.5.4.20=f2a8b7445402b7d89c3bee
403350e5408942a449537c58eb40
0201443, postalCode=380015,
st=Gujarat,
serialNumber=020a2677309e82d6,
Serial105x7763d4174152ca305c67
40706db446b, cn=Ragin Ravindraba
Shah
Date: 2024.10.10 10:45:46 +05'30'



UNDERTAKING: I hereby agree that:

1. This Project is registered under the Capital Expenditure (CAPEX) mode, where the solar PV system is owned by me and electricity generated is used by ME.
2. I have on my OWN selected the Installer upon due diligence and have mutually agreed with the terms and conditions amongst ourselves.
3. I am aware that GEDA has no role whatsoever in the selection of the Installer/Vendor and thus GEDA is not responsible for INSTALLER's technical and financial capabilities, quality and integrity, any kind of delay; financial or technical loss, quality and standards of the system and its components; theft, financial transaction done or any criminal assault occurred because of the selection of the Installer.
4. I am fully responsible for the Solar PV system that will be installed under this application.
5. I am aware that the Gujarat Renewable Energy Policy – 2023 and its amendments thereof under which this project is registered does not have any provision of subsidy or financial assistance.
6. I agree to abide by the provisions of the Gujarat Renewable Energy Policy – 2023 and GERC Net Metering Regulations from time to time of with all amendments thereof.

Yours faithfully

For Gujarat Energy Development Agency

CC To	1. The Chief Engineer UGVCL	With a request for ascertaining the technical feasibility, signing of the connectivity agreement and installation of the bi-directional meter.
	2. The Chief Electrical Inspector	With a request to approve the SLD and grant charging permission for the eligible system capacity.
	3.B Solar Consultant & Engineer	For necessary action, and installation of the solar system upon technical feasibility done by the DISCOM
	4.CEA	With a request to approve the SLD and grant charging permission for the eligible system capacity. (if applicable)

DISCLAIMER: The PV Installer/ Vendor/ EPC Company is selected by the Applicant/Consumer as per his choice, GEDA owning no responsibility of the EPCs for his technical, financial strength quality integrity, etc. and the financial transactions with PV Installer.

(This is Computer generated letter and does not require any signature)

Ragin
Ravindrab
hai Shah

Digitally signed by Ragin Ravindrabhai Shah
DN: c=IN, o=Personal, ou=+9195, pseudonym=DanRaghai1454262b44d3eebdfce,
2.5.4.2b-c2b4d74d45402b76d80c3ee4633e95408942de49517c5eeb40d951483, postalCode=380015,
st=Gujarat,
serialNumber=0206a2677309ae32c,
Subject=05c07f6541711552a2b5c6740766b44a6, cn=Ragin Ravindrabhai Shah
Date: 2024.10.10 10:45:46 +05'30'



Uttar Gujarat Vij Company Limited

CIN : U40102GJ2003SG042906
(A subsidiary of Gujarat Orja Vikas Nigam Limited)

7
Azadi Ka
Amrit Mahotsav

No: UGVCL/R&C/Com/TLE/New/ 2093

Date:- 30/08/2022

BY RPAD

To,
M/s Shree Gyaprasad Jain Cheritable Trust
Office No-35, World Business House
3rd floor, Nr. Parimal Garden,
Ellisbridge.
Ahmedabad-380006

SR No.9864234

Sub: -Your request for approval for extension in time limit for payment of estimate for catering New 150 KVA HT power supply to your proposed unit at. Vill.Bhoyanrathod, Ta.Gandhinagar.

Ref:- 1.Estimate No.:UGVCL/ACE/Tech-1/HT/New/7569 dtd.26/07/2022
2.Your request letter received on dtd.25/08/2022

Dear Consumer,

We have examined your request for extension in time limit for payment of estimate charges; we are pleased to grant the extension of **time limit up to dtd.24-09-2022** subject to the condition that,

1. The Security Deposit shall stand updated to the date of payment.
2. The other provisions of the estimate letter at ref. remain unaltered.

With Regards,

(J. K. Darji)

Chief Engineer (OP)
UGVCL- Mehsana

C.C. to :-

1. ACE, UGVCL, CO, Sabarmati.
2. EE, UGVCL, DO, Gandhinagar U.

.....It is informed to submit the technical feasibility if any change in the same and for necessary actions as mentioned above.

Ragin
Ravindrab
hai Shah

Digitally signed by Ragin Ravindrabha
Shah
DN: c=IN, o=Personal, title=4505,
pseudonym=f9ebfbb114542e5bb44
d35eed01fccc,
2.5.4.20=f264874d45a02b76d89e3be
af63b5e9f5c809842de4f9537f58
59851483, postalCode=380015,
st=Gujarat,
serialNumber=0f260a2fa77309ae82d
5aeeb10fc5f7163cd17415523a365cb
407666044d6, cn=Ragin Ravindrabha
Shah
Date: 2024.10.10 10:45:46 +05'30'



Regd. & Corporate Office: Visnagar Road, MEHSANA - 384 001 (North Gujarat)
Telephone: (02762) 222080-81 **Fax:** (02762) 223574
Website: www.ugvcl.com **e-mail:** corporate@ugvcl.com

Fax: (02762) 223574
e-mail: corporate@ugvel.com

13135116/BJP/01

ઉત્તર ગુજરાત વીજ કંપની લીમીટેડ YY 750734
રસીદ નં. :

ગ્રાહક નંબર : 280/ADALAJ
તારીખ : 27-07-2022

ગ્રાહકનું નામ : 28032/00624/9
રૂ. (શબ્દમાં) : SHREE GAYAPRASADJAINCHERITABAL *314122.00

માટે : ના બીલ પેટે મળ્યા છે.
Three Lakhs Fourteen Thousand
*ચેક/ડી.ડી./કર્ષણ નંબર અને તારીખ : One Hundred And Twenty Two Only
27-07-2022
ભરણાં નો પ્રકાર : CHQ:535 HDFC 27-07-2022
* (ચેકના નાણાં વસુલાતને આધીન) ઉત્તર ગુજરાત વીજ કંપની લીમીટેડ વતી
Energy Charges

SPECIFIC COMPUTER FORMS - AHMEDABAD.

ઉત્તર ગુજરાત વીજ કંપની લીમીટેડ YY 757125
રસીદ નં. :

ગ્રાહક નંબર : 280/ADALAJ
તારીખ : 26-08-2022

ગ્રાહકનું નામ : 28032/00624/9
રૂ. (શબ્દમાં) : SHREE GAYAPRASADJAINCHERITABAL *314122.00

માટે : ના બીલ પેટે મળ્યા છે.
Three Lakhs Fourteen Thousand
*ચેક/ડી.ડી./કર્ષણ નંબર અને તારીખ : One Hundred And Twenty Two Only
26-08-2022
ભરણાં નો પ્રકાર : CHQ:536 HDFC 26-08-2022
* (ચેકના નાણાં વસુલાતને આધીન) ઉત્તર ગુજરાત વીજ કંપની લીમીટેડ વતી

SPECIFIC COMPUTER FORMS - AHMEDABAD.

16:23:34/DJE/01

Ragin
Ravindrab
hai Shah

Digitally signed by Ragin Ravindrabhai Shah
DN: c=IN, ou=Personal, o=K595, pseudonym=23ae9bb11452e53b44
d53eedd1fccc
2.5.4.20=F04687445450267688963bee
a6335e954099420a4f9537c58eb40
d79514b3.postalCode=380015,
st=Gujarat,
serialNumber=0F962a2a77309e82d6
Serial=10F5c7F163d174152ca365c367
40766b44d6, cn=Ragin Ravindrabhai
Shah
Date: 2024.10.10 10:45:46 +05'30'



UGVCL

Uttar Gujarat Vij Company Limited

CIN - U40102GJ2003SGC042808
(A subsidiary of Gujarat Urja Vikas Nigam Limited)

No: UGVCL/ACE/Tech-1/HT/New/ 7569

BY RPAD

Date:

26 JUL 2022

(SR No. 9864234)

To,

SHREE GYAPRASAD JAIN HERITABLE TRUST
OFFICE NO-35, WORLD BUSINESS HOUSE,
3RD FLOOR, NR PARIMAL GARDEN
ELLISBRIDGE
AHMEDABAD-380006
MOBILE NO-0Sub:- Firm quotation for catering 150 KVA HT Power at 11 KV to your proposed unit located at Village-
BHOYANRATHOD, Ta-GANDHINAGAR

- Ref -
- 1) Corporate office letter no. UGVCL/Regd./Com/HT/New-Addl./127,dtd.18.1.16
 - 2) GETCO office Com. Circular no.24, GETCO/CE(R&C)/685, dtd.3.4.20
 - 3) R&C office letter no. UGVCL/R&C/Tech/EOD Business/1010, dtd.18.8.18.
 - 4) UGVCL/R&C/RE/Cost Data-2019-20/274 dated 31.8.19
 - 5) GERC Notification No-3 of 2020 dtd 26.6.20
 - 6) DO proposal no: UGVCL/GNR(U)/TECH-2/HT/4481 DTD:19.07.22
 - 7) Your Registration on dt.15-07-22 & Comply dated -

Dear Sir,

1. As approved by the competent authority your requirement of power of 150 KVA in LS no/ Block no:268- 14375 SQ. MTR, 270-3805 SQ. MTR.,277-2858 SQ. MTR, 278- 23129 SQ. MTR, 279-909 SQ. MTR., (Total: - 45076 sq.mtr.) at Vill. BHOYANRATHOD as above may be met with from the GETCO'S 66 KV MOTI ADRAJ Substation by tapping/proposed 11 KV KRUSHNANAGAR JGY feeder.
2. In case, there are any outstanding dues of previous consumer on the premises you are occupying, you shall have to pay the same in full, failing which power supply will not be given to you.
3. The supply shall be on contingent basis i.e. withdrawable at any time without notice, if the power position so warrants due to shortage of power as may be prevailing at the relevant times
4. Firm quotation (Ann-I) as detailed below is under HTP-I tariff.

Sr No	Item	Amount (Rs.)
1.	Contribution towards cost of capital assets from DISCOM/Beneficiaries on pro-rata basis-(Non Refundable) A/C 47.313. Total amount to be credited at GETCO'S account.(Code no.29.995)	213000.00
2.	The rate for the new HT connection /load extension up to or less than 500 KVA shall be Rs.1500/ KVA as per GERC(licensee's power to recover expenditure incurred in providing supply and other miscellaneous charges)(Second amendment) Regulation,2020.Notification No.3 of 2020 dtd.26.6.2020	225000.00
3.	Actual charges for UG network and the network where separate infrastructural network developed under critical infrastructure project, where government's/developer's contribution is involved.	69447.00
4.	Security Deposit (S.D)	924995.00
5.	Agreement Fees in Rs.	320.00
	TOTAL	1432762.00

Ragin
Ravindrab
hai Shah

Digitally signed by Ragin Ravindrabhai Shah
DN: cn=Ragin Ravindrabhai Shah, o=UGVCL, ou=UGVCL, email=Ragin.Ravindrabhai@ugvcl.co.in, c=IN, serial=1432762, version=1
Reason: I am the author of this document.
Date: 2022.07.26 10:45:46 +05'30'

Uttar Gujarat Vij Company Limited

CIN - U40102GJ2003SGC042906
(A subsidiary of Gujarat Urja Vikas Nigam Limited)

same name of your existing LT connection in the same premises otherwise your connection can not be considered as LT to HT conversion.

18. Before release of power supply you shall provide a separate circuit for lighting meter at your cost to record energy consumed by non-industrial load.
19. Since your contract demand is less than 500 KVA. Hence you have to lay single core 4 nos. of LT cable from transformer section to main distribution panel/junction box and also r,y,b & Neutral PT terminal shall be brought out on cable box of transformer to measure LT side power consumption by LT accucheck.

Work involvement


-UG:0.015 KM+HTMC BY APPLICANT: ONLY APPROVED BRAND HTMC IS TO BE INSTALLED..

Note

- Before release of connection you have to Submit on Rs.300/- notarized consent for not claimmining regarding revenue loss occurred due to Interruption of 11 Krushnanagar JGY Feeder & in future the connection is transferred from JGY to Ind. feeder , then you have to make payment for the line charge.
- Before payment of an estimate clear all pending dues as per norm.
- You have to construct complete compound wall surrounding your approved area & To provide the gate near point of supply.

Thanking You,

Yours faithfully,


Addl. Chief Engineer
Sabarmati

Encl: - Firm quotation, Draft Agreement

fwcs to: The C.E. UGVCL, (OP), Corporate Office Mehsana

Copy to :

1. The SE, GETCO, CO, HIMMATNAGAR
2. The EE, UGVCL, DO, GANDHINAGAR U

- Estimate is to be accepted only after submission of compliance of query raised by this office email dated 21.07.22 confirmation of circle office.
- Before release of HT connection existing LT connection must be PDC and if agreement period is not over then shortfall agreement charge is to be recover from applicant.
- Before payment of an estimate recover all pending dues from applicant as per norm.

25.7.22



a) Before payment of Firm quotation, you have to obtain documents as mentioned in above "notes" at your end.

Ragin
Ravindrab
hai Shah

Digitally signed by Ragin Ravindrabhai
Shah
DN: cn=Ragin Ravindrabhai, o=UGVCL, ou=UGVCL, email=Ragin.Ravindrabhai@ugvcl.co, c=IN
Date: 2024.10.10 10:43:46 +05'30'

Uttar Gujarat Vij Company Limited

CIN - U40102GJ2003SGC042906
(A subsidiary of Gujarat Urja Vikas Nigam Limited)

- d) Report with MR number and date as soon as consumer pays Firm quotation charges. If consumer does not pay Firm quotation within 30 days, please report immediately.
- e) Technically feasibility report of GETCO Authority for this HT connection is to be obtained at your end.
- f) Send two copies of site plan showing point of supply duly signed by him and consumer's authorized person(s) as soon as point of supply is fixed so that execution of agreement is not delayed.
- g) If Firm quotation is likely to increase, he should send revised proposal before execution of work. He should see that actual expenditure does not exceed Firm quotation d amount. If expenditure is likely to increase during execution of work, then same should be recovered before completing the work.
- h) Final bill should be submitted to us through circle office within three months from the deemed or actual date of release of supply, for which additional cable work involve is to be done as per applicant request.
- i) If LT supply is there in the same premises, it should be discontinued positively, recovering due if any, before release of HT supply.
- j) Please note that the work of this Firm quotation may please be taken on hand only after execution of the agreement by the consumer.
- k) Work completion report shall be issued only after work is completed as per scope of the Firm quotation including work pertaining to transmission side as per Circular No. SE (TR.II)/JE/HT Comm : 443 dated 24-1-97.
- l) You are requested to see that arrangement as per above note for measurement of consumption is provided by applicant & connection should be release on completion of above formalities.

Ragin
Ravindraba
hai Shah

Digitally signed by Ragin Ravindraba
Shah
DN: cn=Ragin, o=Personal, title=ESOS,
pseudoym=D2aeR6a114542e5b44
d3eae0f0c,
2.5.4.20=f2d4874485a2076d89e3bee
a6f55e7f9f489a2aef9537c2ee4d
f7951483, postalCode=380015,
st=Gujarat,
serialNumber=f290a2f67739ae2dc
5eebe105cf7163a4741532ca3051a67
60766d4a46, cn=Ragin Ravindraba
Shah
Date: 2024.10.10 10:45:46 +05'30'





Save Energy for Benefit of Self and Nation



UGVCL Uttar Gujarat Vij Company Limited

(A subsidiary of Gujarat Electricity Corporation Limited)

No: UGVCL/ACE/Tech-1/HT/10974

Date: 29 OCT 2022

RYRPAD

(SR No. 9864234)

To:
SHREE GYAPRASAD JAIN HERITABLE TRUST
OFFICE NO-35, WORLD BUSINESS HOUSE
3RD FLOOR, NB PARIMAL GARDEN
ELLISBRIDGE
AHMEDABAD-380008
MOBILE NO-9978955810

Sub: Release of 150 KVA HT Power supply for your unit at: BHOYANRATHOD, Ta-GANDHINAGAR.
(11 KV System)

Ref.: Estimate No. UGVCL/ACE/Tech-1/HT/7569 Dt. 26-07-2022
Estimate Paid on dtd-22-09-2022

Dear Sir,

It is agreed to release 150 KVA power supply during day and night hours. The above load is released on contingent basis i.e. withdrawable at any time without giving any notice if the power position so warrants. This is subject to power cut in force from time to time.

You may please contact our EE, UGVCL, GANDHINAGAR U who will arrange for physical release of supply, for which you have to submit: 1) The Test Report of Electric Wiring of your premises with fees of Rs.20.00, 2) Charging approval of Electrical Inspector for Transformer, VCB etc, 3) VCB approval of UGVCL for contract demand equal or more than 500 KVA.

From the date of release or deemed date of release of power supply, you will be billed on the basis of contract demand of 150 KVA on tariff HTP-I (One).

Before release of this load, you shall provide separate metering arrangement at your cost so as to record energy consumed for non-industrial load.

You shall be responsible for obtaining and maintaining all applicable statutory approvals including Consent to Establish, Consolidated Consent and Authorization from Gujarat Pollution Control Board. Your Electrical connection is liable to be disconnected on directives from any of such Statutory Authorities for non-compliance of the required Approvals.

As per Supply Code provision, if you failed to avail this power supply within Sixty Days from the date of issue of this letter, you will be billed on the basis of contract demand of 150 KVA for monthly minimum charges after expiry of Sixty Days from the date of issue of this letter as per provision of tariff as imposed from time to time.

NOTE:

- Before release of connection you have to Submit on Rs.300/- notarized consent for not claimmining regarding revenue loss occurred due to interruption of 11 Krushnagar JGY Feeder & in future the connection is transferred from JGY to Ind. feeder, then you have to make payment for the line charge.
- Before release of connection clear all pending dues as per norm.
- You have to construct complete compound wall surrounding your approved area & To provide the gate near point of supply.

Thanking You,

Yours faithfully,

Addl. Chief Engineer
Sabarmati

Regd. & Corporate Office:
Vijayaroad, MEHSANA - 384001 Gujarat
Telephone: (02762) 222080-81
Fax: (02762) 223574
e-mail: corporate@ugvcl.com

Circle Office:
Nr. Torrent Power house Railway Crossing,
Sabarmati, Ahmedabad-380005
Telephone: (079) 27500214, 27500981
e-mail: acesbt@ugvcl.com

Ragin
Ravindrab
hai Shah

Digitally signed by Ragin Ravindrabhai
Shah
DN: cn=Ragin, o=Personal, title=AGS,
serialNumber=2ae986114542c2b44
63ae00ffce,
2.5.4.20=(20467445620768903ee
4030c0ff4e98a3ae9023c0eae0)
40951483, postalCode=380015,
o=Ragin,
serialNumber=0206c267330ae2dc,
serialNumber=0206c267330ae2dc,
40766b4466, cn=Ragin Ravindrabhai
Shah
Date: 2022.10.10 10:45:46 +05'30'

